

September 2025

PVJ POWER NEWSLETTER



PVJ Power carries out Successful Type Test of 5 MVA 3 Winding 33 KV ONAN Transformer.

Successful Type Test of 11 KV 630 Amp VCB in 1st attempt for 31.5 kArms for 3 second Short Time Withstand Test at CPRI, Bhopal.



PVJ Power 11 KV 630 Amp VCB HT Panel successfully clears Temperature Rise Type Test at CPRI Test Lab.



**PVJ Power 1600 kVA 33/0.433 KV
Cast Resin Dry Type Transformer
with ON Load Tap Changer
successfully clears Impulse Type
Test at ERDA.**

**Successful Type Test of 4000 Amp LT
Panel in 1st attempt for 70 kArms for 1
second Short Time Withstand Test at
CPRI, Bhopal.**



**Our 4000 Amp LT Panel clears
Temperature Rise & IP55 Type Test
at CPRI, Bhopal.**



Contact:

+91-98166-38097, +91-70189-96212

marketing@pvjpower.in

www.pvjpower.in